



THE EASTERN SPECIALTY COMPANY

OPERATING INSTRUCTIONS

CAT. 253 SERVICE DISCONNECT SHIELD

TESCO offers a Service Disconnect Shield (CAT. 253) which gives meter technicians a quick visual indication of disconnected service by tilting the meter 45°. The Service Disconnect Shield is a cost-effective way to disconnect power while leaving the meter on-site safely and easily.


CAUTION

The TESCO Service Disconnect Shield is for use with 1S and 2S Meter Forms only.





1

Locate and prepare meter socket where disconnect shield is to be inserted.

CAUTION 
Accessing meter socket may require assistance from an authorized technician, especially those enclosed in tamper-sealed meter boxes.

2

Insert disconnect shield into meter socket. Upper and lower blades of disconnect shield should be inserted to their designated meter socket jaws as indicated by arrows  and .

3

With the disconnect shield in place in the meter socket, insert the meter back into the meter socket. Tilt meter 45° clockwise before inserting to align it properly with disconnect shield holes.

Sample setup when meter is inserted in meter box with disconnect shield.

